



Product Service

Attestation of Conformity

No. N8A 052840 0056 Rev. 00

Holder of Certificate: Samwon Act Co., Ltd.

28, Daedong-ro, Sasang-gu
Busan 47035
REPUBLIC OF KOREA

Product: Low voltage switchgear combination
(Terminal block)

Model(s): BPD35-M5z
(Remark: z. direction of cable - R or L)

Parameters:

Rated input voltage:	600 V a.c.
Rated current:	250 A
Rated Cross-Section:	4-16mm ²
Against ingress liquids:	IP20

Tested according to: EN 60947-1:2007/A2:2014
EN 60947-7-1:2009

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: CP5A01158619

Date, 2019-08-26

(Harry Kwon)

Page 1 of 1

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.

CERTIFICATE OF COMPLIANCE

Certificate Number E516852
Report Reference E516852-20201127
Date 2020-December-12

Issued to: SAMWON ACT CO LTD
28 Daedong-ro Sasang-gu
Busan47035 KR

This is to certify that
representative samples of

TERMINAL BLOCKS - COMPONENT
Series BPD:
Cat. No. BPD35-M5, followed by R or L.

Have been investigated by UL in accordance with the component requirements in the Standard(s) indicated on this Certificate. UL Recognized components are incomplete in certain constructional features or restricted in performance capabilities and are intended for installation in complete equipment submitted for investigation to UL LLC.

Standard(s) for Safety: Standard for Terminal Blocks, UL 1059 & CSA C22.2 No. 158

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information

This *Certificate of Compliance* does not provide authorization to apply the UL Recognized Component Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Recognized Component Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Recognized Component Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

